

PROTOCOL OF ANNEALING OF CONCRETE UNDERLAYMENT WITH FLOOR HEATING

TO BE FILLED IN BY THE INVESTOR (CONSTRUCTION SITE INSPECTOR)
– Applicable to a single room: (For example: living room, kitchen, other...)

Type of investment:

- a) Apartment
- b) b) detached house
- c) c) other facility.....

Address:

DAY	TEMPERATURE ADJUSTMENT	REMARKS	DATE	SIGNATURE
1	20°C			
2	30°C			
3	40°C			
4	50°C			
5	50°C			
6	50°C			
7	50°C			
8	50°C			
9	50°C			
10	50°C			
11	50°C			
12	50°C			
13	50°C			
14	50°C			
15	50°C			
16	40°C			
17	30°C			
18	20°C			
19	Turn off the heating system	Measure the level of moisture		
20				
21				
22				
23				
24	20°C			
25	30°C			
26	40°C			
27	50°C			
28	40°C			
29	30°C			
30	20°C			

.....
Date and signature of the fitter
Stamp of the company responsible for installation

.....
Date and legible signature of the Investor (Construction site Inspector)

INFORMATION FOR THE INVESTOR:

Barlinek S.A. shall not be responsible for any assembly carried out contrary to the Assembly Instruction.
Additional information about warranty conditions can be found on www.barlinek.com.pl
BARLINEK S.A. 25-323 Kielce, al. Solidarności 36, Tel. +(48) 41 333 11 11 / Fax +(48) 41 333 00 00
Email: biuro@barlinek.com.pl

Select the appropriate answer under each selection point.

Illegible protocols will be considered invalid.

If a protocol is found to be falsified, the cooperation agreement will be cancelled immediately.

The document is made in three (3) copies: 1 for the Investor, 1 for the Fitter, and 1 to be sent to Barlinek S.A. by the Fitter.

**The protocol is available on www.Barlinek.com.pl*